



Shasta County

DEPARTMENT OF RESOURCE MANAGEMENT
1855 Placer Street, Redding, CA 96001

Paul A. Hellman
Director

Dale Fletcher, CBO
Assistant Director

November 19, 2018

William and Valerie Winterber
14216 Bear Mountain Road
Redding, CA 96003

**CITATION NO. 01_75_18C_026_4500102_23 FOR BEAR MOUNTAIN RV RESORT
WATER SYSTEM NO. 4500102 OCTOBER 2018, FAILURE TO MONITOR FOR
BACTERIOLOGICAL WATER QUALITY**

The Bear Mountain RV Park Water System is classified as a community water system which is required to collect one routine sample per month for coliform bacteria as prescribed under Sections 64423 and 64424 of Title 22, California Code of Regulations (Title 22). During the month of October 2018, the Bear Mountain RV Park Water System did not submit a copy of a laboratory analysis to this office for review by November, 10, 2018, or did not collect its routine bacteriological water sample from the distribution system. Therefore, this Citation is being issued to William and Valerie Winterberg for violating the bacteriological monitoring and reporting requirements for the month of October 2018.

The Bear Mountain RV Park Water System owner is hereby directed to take the following actions:

1. As required under Section 64463.7 of Title 22, provide public notification to customers within one year of this notice of violation. Enclosure 'A' is a format you may use to fulfill the above public notification requirements. If you wish to propose any change to this notification, please contact our office.
2. Provide two types of public notification: 1) Posting in conspicuous locations throughout the area served by the water system; and 2) mail or hand deliver copies to each water user.
3. Complete and return Enclosure 'B' "Certification of Completion of Public Notification" form within 10 days of giving public notice.
4. The Bear Mountain RV Park Water System representatives shall comply with Section 64423, Title 22, CCR, in all future monitoring periods.

☐ Suite 101
AIR QUALITY MANAGEMENT DISTRICT
530 225-5674
Fax 530 225-5237

☐ Suite 102
BUILDING DIVISION
530 225-5761
Fax 530 245-6468

☐ Suite 103
PLANNING DIVISION
530 225-5532
Fax 530 245-6468

☒ Suite 201
ENVIRONMENTAL HEALTH DIVISION
COMMUNITY EDUCATION
530 225-5787
Fax 530 225-5413

☐ Suite 200
ADMINISTRATION
530 225-5789
Fax 530 225-5807

William and Valerie Winterberg
Page 2
November 19, 2018

Failure to comply with the directives of this citation may result in further enforcement action with the possibility of administrative penalties.

Any person who is aggrieved by a citation, order or decision issued under authority delegated to an officer or employee of the state board under Article 8 (commencing with CHSC, Section 116625) or Article 9 (commencing with CHSC, Section 116650), of the Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4), may file a petition with the State Water Board for reconsideration of the citation, order or decision. Appendix 1 to the enclosed Citation contains the relevant statutory provisions for filing a petition for reconsideration (CHSC, Section 116701).

Petitions must be received by the State Water Board within 30 days of the issuance of the citation, order or decision by the officer or employee of the SCEHD. The date of issuance is the date when the SCEHD mails a copy of the citation, order or decision. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day by 5:00 p.m. Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml

Please contact me at 530/225-5787, Monday through Friday, between 8:00 and 8:30 a.m. should you have any questions or concerns.

Sincerely,



Christy Gilbreath
Registered Environmental Health Specialist

CGpw

Enclosure

c via email: Ernie Goff, lifesadventure@att.net